

DEPARTMENT OF THE AIR FORCE

ELECTRIC SERVICE SPECIFICATIONS

1. **PREMISES TO BE SERVED:** Landstuhl Maintenance Site (MTMC / CSU Camp)

2. **ESTIMATED REQUIREMENTS:**

Estimated maximum demand 450 kW

Estimated annual consumption 800,000 kWh

(The US Government is neither obligated to use, nor is it restricted to, the above estimate.)

3. **POINT OF DELIVERY:** see paragraph 6.a.

4. **DESCRIPTION OF ELECTRIC SERVICE:** The EVU shall deliver3.....Phase
.....3..... wire,50..... hertz, alternating current at 20,000 ..Volts.

The voltage of EVU's high-tension line is20,000Volts.

Substation transformers: normal capacity 630 kVA overload capacity is forhours kVA
delta or wye connected, high side ---- , low side --- Lightning arrestors: type ---- .Switching
apparatus: high side, fused disconnects or OCB ----- , interrupting capacity --- kVA; low side,
OCB --- , interrupting capacity ----- kVA.

5. **METERING AND INVOICING:** see paragraph 6.b.

6. **ALTERATIONS AND ADDITIONS:**

a. The point of delivery and the property demarcation are the terminals of the EVU-owned single conductor high tension cable disposal of "USP Auerhahnfalz" (cable to MTML/ Barrier Maintenance = USAFE property), located within the US-owned transformer station Bldg MS 706.

b. The SWRM own 20 KV metering equipment in the US-owned transformer station consist of:
1 each electronic meter with load profile memory for active, reactive and active power (demand)
3 each current transformer 25/5 A
3 each voltage transformer 20,000 / 100V
1 each tariff control receiver
Meter number: 650127

Meter location: DE00052566877S0005000080000000001

- c. Ordered demand: 440 kW
- d. Demand to be made available: 440 kW
- e. If the ordered demand indicated in paragraph 6.c. will exceed within one accounting year by the actual highest demand, this shall be considered as an increase of the ordered demand to the actual demand. In this case the minimum paid demand will be increased accordingly in accordance with para 1.1 of the special contract conditions, attachment 3.b.
- f. An increase of the demand to be made available in accordance with para. 6.d. requires a special previous agreement. The EVU is willing to increase the demand in a reasonable time after payment of the privilege charge.
- g. The switching on the high tension station bldg MS 706 will be performed by the EVU solely, upon notification of the Base Civil Engineer Ramstein Air Base.

7. Data invoices of Stadtwerke Ramstein-Miesenbach:

Consumer: MTMC / CTS-Camp, An der Schwarzbach 17
Contract no.: 5017
Customer no.: 50017

8. Invoices will be submitted to: US Air Force Europe
86 CES / CEN
Gebäude 573
66877 Flugplatz Flugplatz

9. Payment will be made by: DFAS Limestone
DFAS EU, ATTN: AF
Kleber Kaserne, Gebäude 3200, Mannheimer Strasse
67657 Kaiserslautern

10. Technical representative:

The Base Civil Engineer Ramstein Air Base is the technical representative of the Contracting Officer for the purpose of accepting services and verifying invoices.